

CERTIFICATE

No: 000198/03

In accordance with the **CertAlarm** Rules and Certification scheme type 5, as defined in ISO/IEC 17067, we Telefication B.V. certify that the product

HSM2204

is in conformity with the following standard(s)

EN 50131-6 January, 2008

Alarm systems - Intrusion and hold-up systems - Part 6: Power supplies

EN 50131-6/A1 June, 2014

Alarm systems - Intrusion and hold-up systems - Part 6: Power supplies

Digital Security Controls, a div. of Tyco Safety Products Canada Ltd.

3301 Langstaff Road
L4K 4L2 CONCORD
Canada

is authorised to use the CERTALARM Mark on the above mentioned product.

This certificate is valid until:
24 October 2022

Zevenaar, 08 November 2019

Signed on behalf of Telefication B.V.



Jan Willem Verwoert
Project Manager



CERTIFICATE

No: 000198/03 - Annex No 1

Takes into account the following product and variants:

- Product description: I&HAS Power Supply
- Trademark: DSC/Tyco
- Type designation: HSM2204
- Hardware version: UA623 Rev.01
- Software version: Ver. 1.13
- Serial number: N/A

- Product description: I&HAS Power Supply
- Trademark: DSC/Tyco
- Type designation: HSM2300
- Hardware version: UA623 Rev.01
- Software version: Ver. 1.13
- Serial number: N/A

The optional features of the specifications that are included in the product and test report:

Security grade: 2
Environmental class: II
Equipment class: Fixed
Power supply type: A

This equipment can be applied in EN 50131-1 compliant systems up to and including security grade 2.
Electromagnetic emission and safety aspects are not covered by this certificate.

Applied standards:
EN 50131-1:2006 + A1:2009 + A2:2017
EN 50130-4:2001 + A1:2014
EN 50130-5:2011

Factory location:
TYCO INTERNATIONAL DE MEXICO S DE R.L. DE C.V.
ANTONIO MEUCCI YG GONZALEZ CAMARENA # 10002/PARQUE INDUSTRIAL LA VENTANA
87569, Matamoros
Mexico

Storage location:
AnB Rimex SA
Rue de l'Abbaye 89
4040 Herstal
Belgium

CERTIFICATE

No: 000198/03 - Annex No 1

Test Reports:

- Telefication B.V.: 20134032800rev2.0, 14 August 2014
- Nemko Canada Inc.: 238276-1TRFEMC, 05 July 2013
- Nemko Canada Inc.: 233462-1TRFEMC, 22 May 2013
- Telefication: 181001649-025-Ver 1.00, 25 March 2019



CERTIFICATE

No: 000198/03 - Annex No 2

Validity of Certificate:

The Certificate remains valid based upon satisfactory annual factory production control audits for Fire products or biennial factory production control audits for Security products and follow up re-testing as required by CertAlarm scheme rules.

Documents submitted:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement

DISCLAIMER:

The validity of this certificate is limited to products, which are equal to the one(s) examined.